INSTYTUT ENERGETYKI
Instytut Badawczy
Certification and Inspection Department
01-330 Warszawa, ul. Mory 8
tel. +48 22 34 51 200
instytut.energetyki@ien.com.pl

AC 117

CERTIFICATE OF CONFORMITY

No. DZC.522.92.4.2023
Issue No. 01 from 2023.09.20

Name and address of the certificate holder:	**ERKO sp. z o.o. sp. k.** **Lipowa 24 Str., 11-042 Jonkowo, Poland**
Name of the product:	**Terminal lugs**
Type:	**KSSP 12-1695, KSSP 12-50150, KSSP 12-95240**
Manufacturer:	**ERKO sp. z o.o. sp. k.** **Lipowa 24 Str., 11-042 Jonkowo, Poland**
Production plant:	**ERKO sp. z o.o. sp. k., Czeluśnica 80 (k. Jasła),** **38-204 Tarnowiec, Poland**
Parameters and application of product:	**According to appendix** **Cable termination of conductors in medium voltage networks up to 36 kV**
The product meets requirements of the:	**IEC 61238-1-3:2018 (ed. 1.0), EN IEC 61238-1-3:2019/A11:2019**
According to the reports made by:	**Instytut Energetyki; ERKO**
Number of the test reports:	**EWP/46/E/2019-5, EWP/46/E/2019-25, EWP/46/E/2019-10, EWP/46/E/2019-9, EWP/46/E/2019-12; 1/2018, 9/2019, 6/2018, 5/2018, 7/2018**
Period of validity:	**from 20th of September 2023 until 19th of September 2026**

The right to use the certificate of conformity within its validity period applies only to:

- **these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,**
- **certificate holder or his authorized representative.**

The list of evidenced parameters is included in the appendices to the certificate of conformity.
Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1 acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type tests)

pp of the DIRECTOR OF
INSTYTUT ENERGETYKI

dr hab. Grzegorz Tchorek, prof. IEn

Warsaw, 2023.09.20

AC 117

APPENDIX TO THE CERTIFICATE OF CONFORMITY
No. DZC.522.92.4.2023
Issue No. 01 of 2023.09.20

LIST OF EVIDENCED PARAMETERS

Terminal lug name / type	KSSP 12-1695 16 - 95	KSSP 12-50150 50 - 150	KSSP 12-95240 95 - 240
Class - electrical - mechanical	A 1		
Construction / cross-section of Al cables / conductors [mm^2]	RM, RMC, SM / 16 ÷ 240		
Construction / cross-section of Cu cables / conductors [mm^2]	class 5 / 70		
Initial scatter δ [1)]	≤ 0,30		
Mean scatter β [2)]	≤ 0,30		
Resistance factor ratio λ [3)]	≤ 2,0		
Change in resistance factor D [4)]	≤ 0,15		
Maximum temperature θ_{max} [5)]	≤ θ_{ref}		
Permissible tensile force [N]	≤ 40 x A [6)] Al ≤ 60 x A [6)] Cu [7)]		

NOTES:

1) [1)] The average value of the resistance factors of six connectors before the first heating cycle.
2) [2)] The average value of the resistance factors of six connectors calculated from last 11 measurements readings. It specifies if all connectors of given type are characterized by similar changes in resistance during the heat cycles.
3) [3)] Resistance factor ratio of tested connector during the heat cycle test in relation to the initial resistance factor.
4) [4)] The value specifies the size of the resistance factor change based on last 11 measurements readings.
5) [5)] Temperature of the connector referenced to the temperature of the reference section.
6) [6)] Nominal cross-sectional area
7) [7)] Applies to the KSSP 12-1695